SOUTHWEST FLORIDA WATER MANAGEMENT DISTRICT 2379 BROAD STREET

BROOKSVILLE, FLORIDA 34604-6899

TELEPHONE: 352-505-2970 FAX: 352-754-3497

November 17, 2023



RFB 23-4226 – ROMP 88.5 Northeast Polk County Florida Monitor Well Construction Services

ADDENDUM #1 (Acknowledgment is Required)

The Respondent shall acknowledge its review and receipt of this Addendum by signing below and including a signed copy of this Addendum with its bid submittal. Failure to do so could result in disqualification of the bid.

Please note that underlined information ($\underline{example}$) is added wording and stricken information ($\underline{example}$) is deleted wording.

I. QUESTIONS AND ANSWERS:

1. Question: What is the budget for this project?

Answer: The current estimated budget for this project is \$2,616,403.00.

2. Question: Is there an engineer's estimate available for bid bond purposes?

Answer: No, there is not an engineer's estimate available. Please reference the budget information in Question 1 for the purposes of the bid bond.

3. Question: Can we work 24/7?

Answer: No, a 24/7 work schedule is not permitted. Please reference Section 2.40 Hours of Work for the hours of operation allowed.

4. Question: Can you provide the lithologic data for the site?

Answer: Please refer to Attachment 1 for the complete lithologic data for ROMP 88.5.

5. Question:

In reference to the steel casing noted in the specs, is there any certain grade steel wanted? The drawing shows galvanized- is this true or do they want industry standard carbon steel? A53B?

Answer:

All well casing shall conform to one of the following standards: American Society for Testing and Materials (ASTM) A53/A53M-99b (1999), A135-01 (2001), A252-98 (1998), A589-96 (1996), or American Petroleum Institute (API) 5L-2000 (2000). Well casing that conforms to any of the aforementioned ASTM or API standards shall also conform to the 2000 American National Standard Institute for Welded and Seamless Wrought Steel Pipe (ANSI/ASME B36.10M-2000). All well casing shall be stenciled with the applicable standard, or proper documentation of manufacturer specifications must be supplied to the permitting authority upon request.

Celeste Larisey Procurement Specialist cc: Project Manager

$\Delta CKNOWI$	EDGEMENT OF	ADDENDLIM #1
		ADDLINDUM # 1

BY:	
	DATE
	(TYPE/PRINT NAME AND TITLE)
	COMPANY NAME

End of Addendum #1 for RFB 23-4226