SOUTHWEST FLORIDA WATER MANAGEMENT DISTRICT 2379 BROAD STREET

BROOKSVILLE, FLORIDA 34604-6899

TELEPHONE: 352-505-2970 FAX: 352-754-3497



February 9, 2023

RFB 22-3944 - MONITOR WELL CONSTRUCTION SERVICES

ADDENDUM #2 (Acknowledgment is Required)

The Respondent shall acknowledge its review and receipt of this Addendum by signing below and including a signed copy of this Addendum with its bid submittal, or as stated in Section 4.1, Basis for Award of Agreement of the RFB. Failure to do so could result in disqualification of the bid.

Please note that underlined information ($\underline{example}$) is added wording and stricken information ($\underline{example}$) is deleted wording.

I. CLARIFICATIONS:

- 1. The due date has been changed from February 7, 2023, to February 14, 2023, at 2 P.M. local time.
- 2. 3.4.1 WELL TO WELL SET UP Contractor will be paid up to two (2) hours four (4) hours of the EQUIPMENT RATE (NO DRILLING), submitted on the Bid Response Form to set up drill equipment on each well outlined in the Agreement.
- 3. The District requests that the awarded contractor begin work with the deepest well first. The deepest well will reach a depth of 2,500 feet.

II. QUESTIONS AND ANSWERS:

1. Question: What brand of formation packers does the District plan on supplying?

Answer: The District's preference for the formation packers are Wester Rubber & Manufacturing Shale Traps for PVC casing and various brand Cement Baskets for the steel casings.

2. Question: Should there be a concern for the bid going out to rebid if the

engineers estimate is not obtainable?

Answer: The District has the ability to place any project out for rebid if extenuating circumstances became a factor, such as but not limited to: a solicitation receiving no bids, all bids coming back exponentially over budget, etc. The District does not feel that this should be a concern at this point in time in relation to this solicitation.

3. Question: Is the county willing to make this a time and materials contract?

Answer: This project is being solicited by the Southwest Florida Water Management District, not by Polk County. At this time, the District will not be considering a time and materials contract.

4. Question: Would the county absolutely not work 24/7?

Answer: This project is being solicited by the Southwest Florida Water Management District, not by Polk County. The work schedule will be a minimum of 40 hours per week between the hours of 7 am and 7 pm, typically Monday – Friday. A 24/7 working schedule is not an option for this project.

5. Question: What voltage of electricity is on site?

Answer: The electricity on site is 240 volts single phase.

6. Question: How far away are the temporary well sites located in relation to the permanent well sites?

Answer: The temporary well sites should be between 50 – 150 feet north to northeast of the permanent wells.

Celeste Larisey
Procurement Specialist
cc: Project Manager

ACKNOWLEDGEMENT OF ADDENDUM #2

BY:	
	DATE
	(TYPE/PRINT NAME AND TITLE
	•
	001/01/01/01/01

End of Addendum #2 for RFB 22-3944