



An Equal
Opportunity
Employer

Southwest Florida Water Management District

2379 Broad Street, Brooksville, Florida 34604-6899

(352) 796-7211 or 1-800-423-1476 (FL only)

WaterMatters.org

Bartow Office

170 Century Boulevard
Bartow, Florida 33830-7700
(863) 534-1448 or
1-800-492-7862 (FL only)

Sarasota Office

78 Sarasota Center Boulevard
Sarasota, Florida 34240-9770
(941) 377-3722 or
1-800-320-3503 (FL only)

Tampa Office

7601 U.S. 301 North (Fort King Highway)
Tampa, Florida 33637-6759
(813) 985-7481 or
1-800-836-0797 (FL only)

Kelly S. Rice

Chair, Citrus, Lake, Levy, Sumter

Joel Schleicher

Vice Chair, Charlotte, Sarasota

Rebecca Smith

Secretary, Hillsborough, Pinellas

James G. Murphy

Treasurer, Polk

Ed Armstrong

Pinellas

Ashley Bell Barnett

Polk

Jack Bispham

Manatee

Roger Germann

Hillsborough

John Mitten

Hernando, Marion

Seth Weightman

Pasco

Michelle Williamson

Hillsborough

Brian J. Armstrong, P.G.

Executive Director

February 8, 2021

Set 2

TO: All Potential Respondents

RFP 2105 – TAMPA BOARDROOM AUDIO/VISUAL AND VIDEO UPGRADES

FROM: Brian Bickhardt, Senior Procurement Specialist III

SUBJECT: Response to Questions

1. Under Part IV. AV CONTRACTOR PROVIDED EQUIPMENT, Section E. UTILITY COMPUTER, the product listed is as follows: QTY 1: SL-1U-LLH310M-LA Rack-Mountable Windows 10 Utility PC. The operating system is optional. What is the operating system desired?

The District requires Microsoft Windows 10 Professional, 64 Bit.

2. Remote antennas are not mentioned or specified. Are remote antennas planned, desired, existing or will local antennas in the rack room be planned or desired?

We did not spec remote antennas. We do not believe remote antennas will be needed because of the close location of the rack equipment. Installers will utilize the RG58 Jumpers provided with the Wireless Receivers to extend the Antennas to the back frame of the rack.

3. What cable part number is to be used for RS-422 cabling?

- a. The only listed plenum rated / shielded cable with 4 conductors is Cresnet-P-TL.

- b. Belden 2413 is a plenum rated / shielded cable.

Crestron Cresnet-P-TL will be used for both RS-422 Cables and Cresnet Connections.

4. Panasonic offers premium service & support with accident coverage on their professional video products. Does SFWMD want premium service & support with accident coverage for the Panasonic Pro Video Products?

The District RFP requires a full 2 year warranty for all products.

Panasonic products have a one year warranty included.

Accident Coverage is not required. Additional two year warranty is available through Panasonic.

(Panasonic Switcher and Camera Controller - SKU- AJ-SVCPREF 2Y)

(Panasonic Cameras - SKU- AG-SVCPREF 2Y)

5. What cable part number and connectors are to be used for the Crestron HD-EXT3-C-B_ Systems?

a. The manufacturer recommends DM-CBL-8G-P-SP-XXXX or DM-CBL-ULTRA-P-SP-XXXX cable types.

b. The manufacturer recommends DM-CONN for the connector type.

Belden 2183R 4K UHD Media Cable, 4 Pair 23awgPBC Jacket is specified for CAT6A Cables.

Crestron recommended and manufactured CAT6A Cable is acceptable.

Plenum Cable is not required for these cable runs.

Crestron DM-CONN connectors are acceptable.

6. The Atmos ATOMSHSTU2 does not have any storage media (s) specified.

a. Please specify if hard drive(s) or other media type(s) are required and part number(s) or specification(s) if the AV contractor is to provide.

Media hard drives will be provided by the District.