



An Equal
Opportunity
Employer

Southwest Florida Water Management District

2379 Broad Street, Brooksville, Florida 34604-6899

(352) 796-7211 or 1-800-423-1476 (FL only)

WaterMatters.org

Bartow Office

170 Century Boulevard
Bartow, Florida 33830-7700
(863) 534-1448 or
1-800-492-7862 (FL only)

Sarasota Office

78 Sarasota Center Boulevard
Sarasota, Florida 34240-9770
(941) 377-3722 or
1-800-320-3503 (FL only)

Tampa Office

7601 U.S. 301 North (Fort King Highway)
Tampa, Florida 33637-6759
(813) 985-7481 or
1-800-836-0797 (FL only)

Mark Taylor

Chair, Hernando, Marion

Michelle Williamson

Vice Chair, Hillsborough

Joel Schleicher

Secretary, Charlotte, Sarasota

Kelly S. Rice

Treasurer, Citrus, Lake, Levy,
Sumter

Jack Bispham

Manatee

Roger Germann

Hillsborough

James G. Murphy

Polk

Rebecca Smith

Hillsborough, Pinellas

Seth Weightman

Pasco

Brian J. Armstrong, P.G.

Executive Director

May 1, 2020

Set 1

TO: All Potential Respondents

RFB 2008 – Sarasota Service Office Glass Replacement - Building 1

FROM: Brian Bickhardt, Senior Procurement Specialist III

SUBJECT: Response to Questions

QUESTION: Will any construction drawings be released?

ANSWER: No, since this is a replacement of existing windows. If drawings are required for permitting, they will be supplied by the Contractor.

QUESTION: Will any pictures be released?

ANSWER: The District will not be releasing pictures, but the Contractor is able to utilize the Non-Mandatory Pre-Bid and Site Visit on May 12, 2020 @ 9:30 a.m. to visually inspect and take pictures.

QUESTION: Interior repairs to sills be required?

ANSWER: Yes, new metal sill closures are required.

QUESTION: Structural repairs to existing openings?

ANSWER: The existing masonry openings are in good shape and repairs are not anticipated. This will be addressed in the field on an as needed basis.