



May 7, 2024

RFQ 24-4403 CAMPUS GENERATOR PREVENTIVE MAINTENANCE SERVICES

**ADDENDUM #2
(Acknowledgment is Required)**

The Respondent shall acknowledge its review and receipt of this Addendum by signing below and including a signed copy of this Addendum with its bid submittal. Failure to do so could result in disqualification of the bid.

Please note that underlined information (*example*) is added wording and stricken information (*example*) is deleted wording.

I. CLARIFICATIONS

1. Please note, the following requirement has been added to As-Needed Services section 6, Generator Load Bank Testing: The Generator Load Bank Testing will be performed in accordance with the National Fire Protection Association Code 110.
2. Please note, Bidders shall submit the completed Addendum 2 signature page with their quote submission.

II. QUESTIONS AND ANSWERS

1. **Question:** **How many hours do you want the generator Load Bank Testing (2 hrs., 4 hrs. etc. etc.)?**

Answer: The Generator Load Bank Testing will be performed in accordance with the National Fire Protection Association Code 110.

Ari Horowitz
Procurement Specialist
cc: Project Manager

ACKNOWLEDGEMENT OF ADDENDUM #2

BY: _____ DATE

(TYPE/PRINT NAME AND TITLE)

COMPANY NAME

End of Addendum #2 for RFQ 24-4403